



**Gateway Greens South
Surface Water Management
System Facilities Cleaning and Repairs
Specifications & Contract**

ADDENDUM #2

May 21, 2018

This notice is being provided to all prospective bidders to clarify or change information or answer questions submitted for the above bid document.

The following written questions/statements were submitted for review.

QUESTIONS AND ANSWERS

Question 1 Please confirm that there is sufficient access along the golf course to access all structures required to be cleaned (both legal access IE easements, and physical access).

Answer: There are existing easements. Gateway will coordinate with the Golf Course Superintendent during the project.

Question 2 Please clarify who is responsible for restoration along the access way to include sod, tire rutting, sprinkler heads, tree trimming, cart path, etc. for all work adjacent to golf course.

Answer: Per the specifications, the contractor is responsible for restoration work.

Question 3 Please clarify the statement made in the pre-bid meeting regarding the ability to decant and dewater the separated solids back into the on-site catch basins and lakes by use of a geotextile filter bag? The contract documents (Section 4.18) currently do not address the deposition of dewatering from the pipes and catch basins, it only

prohibits the release of solids. If the intention is to prohibit any water from being returned into the catch basins and or lakes then the GSCDD should be aware that the cost of this project will be substantially higher and we see no benefit to be gained from this approach. Regardless of the method (either vac trucks or divers) water will have to be released on site. This is standard practice across the industry for all areas.

Answer: Water can re-enter the stormwater system.

Question 4 Please clarify who will manage this project from the GSCDD side as the Resident Project Representative and who will be responsible for on-site inspections during construction.

Answer: Michael P. Tisch, Publics Works Manager, GSCDD

Question 5 Please clarify the requirements for post cleaning inspections of pipes. Is a stationary camera at one side of the pipe sufficient, or is a remote camera required to be passed through the pipe and inspect the entirety of the cleaning/repair?

Answer: Remote Video Camera inspection through pipe.